

**CITY OF LA PALMA
COMMUNITY SERVICES DEPARTMENT**

ADDENDUM NO. 1

**WATER MAIN INTERCONNECT PROJECT
CITY PROJECT NO. 22-WTR-02**

MAY 15, 2023

TO ALL MANDATORY PRE-BID MEETING ATTENDEES:

Clarifications/Questions from Contractors.

The following addresses questions and offers clarifications for the project referenced above received by the City from Contractors who attended the mandatory pre-bid meeting and the information below will be incorporated into the project per this Addendum.

1. MANDATORY PRE-BID MEETING ATTENDANCE SHEET:

Attached is the sign-in sheet from the Mandatory Pre-Bid meeting for the project on May 9, 2023.

2. QUESTIONS FROM CONTRACTORS AND RESPONSES

The City has received the following questions and provides responses in bold.

“Has the City confirmed the dimensional clearance and elevations to ensure the 16” insertion valve will not impair the Contractor’s ability to cover and pave after installation?”

There is dimensional clearance of +/- 3'-5" to allow paving.

“Will this project require the Contractor to backfill the trench and restore asphalt per the City of La Palma or City of Cerritos Standard? Will pavement reinforcement fabric be required?”

Trench backfill shall follow City of Cerritos standards. Pavement fabric will not be required.

“If small quantity of AHRM is not available for weeks or months following installation, will this be an issue for the City?”

Due to small quantity issues, use standard asphalt for all paving on the project.

“Will the contractor be responsible for obtaining pricing and lead time for materials?”

Yes, the contractor will be responsible for obtaining and pricing of all project materials. The City is NOT providing any materials.

The project bid date and time does NOT change.

Please sign below and attach this "ACKNOWLEDGMENT OF RECEIPT", Addendum No. 1 with the Bid submittal documents. **Failure to submit the signed Addendum No. 1 Acknowledgement will render the contractor's bid as non-responsive.** Thank you for your cooperation.

Sincerely,



Douglas Benash, P.E.
City Engineer

ACKNOWLEDGMENT OF RECEIPT: Addendum No. 1

Company Name

Date

By _____

Signature

Attachment: Pre-Bid Meeting Sign In Sheet.



City of La Palma
Pre-Bid Meeting Sign in Sheet
Date: May 9, 2023 at 2:30pm

Project Name: Water Main Interconnect Project
Project Number: 22-WTR-02

| | <u>Name</u> | <u>Company</u> | <u>Email</u> | <u>Cell Number</u> |
|----|-------------------|-----------------------------|--|-------------------------|
| 1 | Rachel Rutherford | Valverde Construction | rachelra@valverdeconst.com | (562) 724-0781 |
| 2 | Richard Valencia | Bonadiman Water Inc | bonwatering@gmail.com | (951) 657-0200 |
| 3 | Artie Saldaña | Big Ben Inc | artie@bigbenengr.com | (562) 786-1721 |
| 4 | Glen Pool | Doty Bros. | gpool@dotybros.com | (602) 202-8277 |
| 5 | Christian Jaime | CRP Contractors | info@grpcontractors.com | (714) 658-2202 |
| 6 | CHRISTIAN ROSALES | Dominguez General Eng. Inc. | dominguezgeneral@aol.com | (626) 998-5179 |
| 7 | ANDY RAMIREZ | CITY OF LA PALMA | RAMIREZ@CITY OF LA PALMA.ORG | |
| 8 | Jaike Chavira | City of La Palma | JChavira@CITY OF LA PALMA.ORG | 714-690-3313 |
| 9 | Shen Camo | City of La Palma | scamo@CITY OF LA PALMA | (714) 690-3325 |
| 10 | Douglas Benash | City of La Palma | benash@CITY ENGINEER@CITY OF LA PALMA.ORG | 626 203 2899 |
| 11 | | | | |
| 12 | | | | |
| 13 | | | | |