



---

CITY OF LA PALMA  
COMMUNITY SERVICES  
DEPARTMENT

---

# 2018 Water Quality Report

DATA FOR 2017

# Your 2018 Water Quality Report

State  
Water  
Project

Since 1990, California public water utilities have been providing an annual Water Quality Report to their customers. **This year's report covers calendar year 2017 drinking water quality testing and reporting.** Your City of La Palma Community Services Department (City) vigilantly safeguards its water supply and, as in years past, the water delivered to your home meets the quality standards required by federal and state regulatory agencies. The U.S. Environmental Protection Agency (USEPA) and the State Water Resources Control Board, Division of Drinking Water (DDW) are the agencies responsible for establishing and enforcing drinking water quality standards.

In some cases, the City goes beyond what is required by testing for unregulated chemicals that may have known health risks but do not have drinking water standards. For example, the Orange County Water District (OCWD), which manages the ground water basin, and the Metropolitan Water District of Southern California (MWDSC), which supplies treated imported surface water to the City, both test for unregulated chemicals in our water supply. Unregulated chemical monitoring helps USEPA and DDW determine where certain chemicals occur and whether new standards need to be established for those chemicals to protect public health.

Through drinking water quality testing programs carried out by OCWD for groundwater, MWDSC for treated surface water, and the City for the water distribution system, your drinking water is constantly monitored from source to tap for regulated and unregulated contaminants.

The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Therefore, some of our data, though representative, is more than one year old.



# The Quality of Your Water Is Our Primary Concern

## Sources of Supply

Orange County's water supplies are a blend of groundwater managed by the Orange County Water District (OCWD) and water imported from Northern California and the Colorado River by the Municipal Water District of Orange County (MWDOC) via Metropolitan Water District of Southern California (MWDSC). Groundwater comes from a natural underground aquifer that is replenished with water from the Santa Ana River, local rainfall, and imported water. The groundwater basin is 350 square miles and lies beneath north and central Orange County from Irvine to the Los Angeles County border and from Yorba Linda to the Pacific Ocean. More than 20 cities and retail water districts draw from the basin to provide water to homes and businesses.

## Orange County's Water Future

For years, Orange County has enjoyed an abundant, seemingly endless supply of high-quality water. However, as water demand continues to increase statewide, we must be even more conscientious about our water supply and maximize the efficient use of this precious natural resource.

OCWD and MWDOC work cooperatively to evaluate new and innovative water management and supply development programs, including water reuse and recycling, wetlands expansion, recharge facility construction, ocean and brackish water desalination, surface storage, and water use efficiency programs. These efforts are helping to enhance long-term countywide water reliability and water quality.

A healthy water future for Orange County rests on finding and developing new water supplies, as well as protecting and improving the quality of the water that we have today. Your local and regional water agencies are committed to making the necessary investments today in new water management projects to ensure an abundant and high-quality water supply for our future.



## Basic Information About Drinking Water Contaminants

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the layers of the ground it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animal and human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production or mining activities.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gasoline stations, urban stormwater runoff, agricultural application, and septic systems.



- **Inorganic contaminants**, such as salts and metals, can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining, and farming.

In order to ensure that tap water is safe to drink, USEPA and the DDW prescribe regulations that limit the amount of certain contaminants in water provided by public water systems.

The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at (800) 426-4791.

## Drinking Water Fluoridation

Fluoride has been added to U.S. drinking water supplies since 1945. Of the 50 largest cities in the U.S., 43 fluoridate their drinking water. In December 2007, the MWDSC joined a majority of the nation's public water suppliers in adding fluoride to drinking water in order to prevent tooth decay. In line with recommendations from the DDW, as well as the U.S. Centers for Disease Control and Prevention, MWDSC adjusted the natural fluoride level in imported treated water from the Colorado River and State Water Project to the optimal range for dental health of 0.6 to 1.2 parts per million. Our local water is not supplemented with fluoride. Fluoride levels in drinking water are limited under California state regulations at a maximum dosage of 2 parts per million.



There are many places to go for additional information about the fluoridation of drinking water.

**U.S. Centers for Disease Control and Prevention:** [www.cdc.gov/fluoridation/](http://www.cdc.gov/fluoridation/)  
**State Water Resources Control Board, Division of Drinking Water**  
[www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/Fluoridation.html](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/Fluoridation.html)

For more information about MWDSC's fluoridation program, please contact Edgar G. Dymally at (213) 217-5709 or at [edyally@mwdh2o.com](mailto:edyally@mwdh2o.com).

### Questions about your water? Contact us for answers.

For information about this report, or your water quality in general, please contact the Community Services Department at (714) 690-3310.

The City Council meets on the 1st and 3rd Tuesday of every month at 7:00 p.m. in the City Council Chambers located at 7822 Walker Street, La Palma, California 90623. Please feel free to participate in these meetings.

For more information about the health effects of the listed contaminants in the following tables, call the USEPA hotline at (800) 426-4791.

# Federal and State Water Quality Regulations

## — Water Quality Issues that Could Affect Your Health —

### Disinfectants and Disinfection Byproducts

Disinfection of drinking water was one of the major public health advances in the 20<sup>th</sup> century. Disinfection was a major factor in reducing waterborne disease epidemics caused by pathogenic bacteria and viruses, and it remains an essential part of drinking water treatment today.

Chlorine disinfection has almost completely eliminated from our lives the risks of microbial waterborne diseases. Chlorine is added to your drinking water at the source of supply (groundwater well). Enough chlorine is added so that it does not completely dissipate through the distribution system pipes. This “residual” chlorine helps to prevent the growth of bacteria in the pipes that carry drinking water from the source into your home.

However, chlorine can react with naturally-occurring materials in the water to form unintended chemical byproducts, called disinfection

byproducts (DBPs), which may pose health risks. A major challenge is how to balance the risks from microbial pathogens and DBPs. It is important to provide protection from these microbial pathogens while simultaneously ensuring decreasing health risks from disinfection byproducts. The Safe Drinking Water Act requires the USEPA to develop rules to achieve these goals.

Trihalomethanes (THMs) and Haloacetic Acids (HAAs) are the most common and most studied DBPs found in drinking water treated with chlorine. In 1979, the USEPA set the maximum amount of total THMs allowed in drinking water at 100 parts per billion as an annual running average. Effective in January 2002, the Stage 1 Disinfectants / Disinfection Byproducts Rule lowered the total THM maximum annual



### What are Water Quality Standards?

Drinking water standards established by USEPA and DDW set limits for substances that may affect consumer health or aesthetic qualities of drinking water. The chart in this report shows the following types of water quality standards:

- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Secondary MCLs:** Set to protect the odor, taste, and appearance of drinking water.
- **Primary Drinking Water Standard:** MCLs for contaminants that affect health along with their monitoring and reporting requirements and water treatment requirements.
- **Regulatory Action Level (AL):** The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements that a water system must follow.

### How are Contaminants Measured?

Water is sampled and tested throughout the year. Contaminants are measured in:

- parts per million (ppm) or milligrams per liter (mg/L)
- parts per billion (ppb) or micrograms per liter (µg/L)
- parts per trillion (ppt) or nanograms per liter (ng/L)

### What is a Water Quality Goal?

In addition to mandatory water quality standards, USEPA and DDW have set voluntary water quality goals for some contaminants. Water quality goals are often set at such low levels that they are not achievable in practice and are not directly measurable. Nevertheless, these goals provide useful guideposts and direction for water management practices. The chart in this report includes three types of water quality goals:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by USEPA.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

### 2017 City of La Palma Drinking Water Quality Local Groundwater and Imported Metropolitan Water District Treated Surface Water

Chemical	MCL	PHG (MCLG)	Avg. Groundwater Amount	Avg. Imported MWD Amount	Range of Detections	MCL Violation?	Typical Source of Contaminant
<b>Radiologicals – Tested in 2014 and 2017</b>							
Uranium (pCi/L)	20	0.43	0.63	ND	ND – 1.25	No	Erosion of Natural Deposits
<b>Inorganic Chemicals – Tested in 2017</b>							
Aluminum (ppm)	1	0.6	ND	0.16	ND – 0.13	No	Treatment Process Residue, Natural Deposits
Arsenic (ppb)	10	0.004	6.8	ND	ND – 10	No	Erosion of Natural Deposits
Fluoride (ppm) naturally-occurring	2	1	0.44	NR	0.43 – 0.44	No	Erosion of Natural Deposits
Fluoride (ppm) treatment-related	Control Range 0.6 – 1.2 ppm Optimal Level 0.7 ppm		NR	0.7	0.6 – 0.9	No	Water Additive for Dental Health
<b>Secondary Standards* – Tested in 2017</b>							
Aluminum (ppb)	200*	600	ND	160	ND – 130	No	Erosion of Natural Deposits
Chloride (ppm)	500*	n/a	16.2	50	14.1 – 66	No	Runoff or Leaching from Natural Deposits
Color (color units)	15*	n/a	1.5	1	1 – 2	No	Naturally-occurring Organic Materials
Manganese (ppb)	50*	n/a	47.3	ND	ND – 52.2	No	Erosion of Natural Deposits
Odor (threshold odor number)	3*	n/a	2	2	1 – 2	No	Naturally-occurring Organic Materials
Specific Conductance (µmho/cm)	1,600*	n/a	478	490	351 – 630	No	Substances that Form Ions in Water
Sulfate (ppm)	500*	n/a	49.2	96	42.6 – 127	No	Runoff or Leaching from Natural Deposits
Total Dissolved Solids (ppm)	1,000*	n/a	303	294	213 – 374	No	Runoff or Leaching from Natural Deposits
Turbidity (NTU)	5*	n/a	0.15	ND	ND – 0.2	No	Runoff or Leaching from Natural Deposits
<b>Unregulated Chemicals – Tested in 2017</b>							
Alkalinity, total as CaCO <sub>3</sub> (ppm)	Not Regulated	n/a	169	61	48 – 178	n/a	Runoff or Leaching from Natural Deposits
Boron (ppm)	NL = 1	n/a	< 0.1	0.1	ND – 0.1	n/a	Runoff or Leaching from Natural Deposits
Calcium (ppm)	Not Regulated	n/a	41.4	28	20 – 43.6	n/a	Runoff or Leaching from Natural Deposits
Hardness, total (ppm)	Not Regulated	n/a	141	119	82 – 156	n/a	Runoff or Leaching from Natural Deposits
Hardness, total (grains/gallon)	Not Regulated	n/a	8.3	7	4.8 – 9.1	n/a	Runoff or Leaching from Natural Deposits
Magnesium (ppm)	Not Regulated	n/a	9	12	8 – 16	n/a	Runoff or Leaching from Natural Deposits
pH (pH units)	Not Regulated	n/a	7.8	8.4	7.7 – 8.6	n/a	Hydrogen Ion Concentration
Potassium (ppm)	Not Regulated	n/a	2.1	2.8	1.9 – 3.2	n/a	Runoff or Leaching from Natural Deposits
Sodium (ppm)	Not Regulated	n/a	48.5	51	39 – 63	n/a	Runoff or Leaching from Natural Deposits
Total Organic Carbon (ppm)	TT	n/a	ND	2.4	1.8 – 3.0	n/a	Various Natural and Man-made Sources

ppb = parts-per-billion; ppm = parts-per-million; pCi/L = picoCuries per liter; NTU = nephelometric turbidity units; µmho/cm = micromhos per centimeter; NR = Not Required to be analyzed; ND = not detected; < = average is less than the detection limit for reporting purposes; MCL = Maximum Contaminant Level; (MCLG) = federal MCL Goal; PHG = California Public Health Goal; NL = Notification Level; n/a = not applicable \*Contaminant is regulated by a secondary standard.

Turbidity – combined filter effluent Metropolitan Water District Diemer Filtration Plant	Treatment Technique	Turbidity Measurements	TT Violation?	Typical Source of Contaminant
1) Highest single turbidity measurement	0.3 NTU	0.08	No	Soil Runoff
2) Percentage of samples less than 0.3 NTU	95%	100%	No	Soil Runoff

Turbidity is a measure of the cloudiness of the water, an indication of particulate matter, some of which might include harmful microorganisms. Low turbidity in Metropolitan's treated water is a good indicator of effective filtration. Filtration is called a "treatment technique" (TT). A treatment technique is a required process intended to reduce the level of contaminants in drinking water that are difficult and sometimes impossible to measure directly.

### Unregulated Chemicals Requiring Monitoring

Chemical	Notification Level	PHG	Average Groundwater	Average Imported MWD Water	Range of Detections	Most Recent Sampling
Chlorate (ppb)	800	n/a	120	68	64 – 170	2013
Chromium, Hexavalent (ppb)	n/a	0.02**	ND	0.06	ND – 0.06	2013
Molybdenum, Total (ppb)	n/a	n/a	16	4.5	4.5 – 19	2013
Strontium, Total (ppb)	n/a	n/a	530	900	490 – 900	2013
Vanadium, Total (ppb)	50	n/a	<0.2	2.9	ND – 2.9	2013

\*\*There is currently no MCL for hexavalent chromium. The previous MCL of 10 ppb was withdrawn on September 11, 2017.

average level to 80 parts per billion and added HAAs to the list of regulated chemicals in drinking water. Your drinking water complies with the Stage 1 Disinfectants / Disinfection Byproducts Rule.

Stage 2 of the regulation was finalized by USEPA in 2006, which further controls allowable levels of DBPs in drinking water without compromising disinfection itself. A required distribution system evaluation was completed in 2008 and a Stage 2 monitoring plan has been approved by DDW. Full Stage 2 compliance began in 2012.

## About Lead in Tap Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children.

Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or on the internet at: [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).



The USEPA and the federal Centers for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from USEPA's Safe Drinking Water Hotline at (800) 426-4791 between 10 a.m. and 4 p.m. Eastern Time (7 a.m. to 1 p.m. in California).

## Arsenic Advisory

While your drinking water meets the federal and state standard for arsenic of 10 micrograms per liter, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. The USEPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems. Additional information on arsenic is available from the EPA website, [www.epa.gov/safewater/arsenic](http://www.epa.gov/safewater/arsenic).

## Immunocompromised People

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised people, such as those with cancer who are undergoing chemotherapy, persons who have had organ transplants, people with HIV/AIDS or other immune system disorders, some elderly persons, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.



## Cryptosporidium

*Cryptosporidium* is a microscopic organism that, when ingested, can cause diarrhea, fever, and other gastrointestinal symptoms. The organism comes from animal and/or human wastes and may be in surface water.

MWDSC tested their source water and treated surface water for *Cryptosporidium* in 2017 but did not detect it. If it ever is detected, *Cryptosporidium* is eliminated by an effective treatment combination including sedimentation, filtration, and disinfection.

### Want Additional Information?

There's a wealth of information on the internet about Drinking Water Quality and water issues in general. A good place to begin your own research is the City of La Palma website:

[www.CityofLaPalma.org](http://www.CityofLaPalma.org)

In addition to extensive information about your local water and the support and services we offer, you'll find links for many other local, statewide, and national resources.

## Source Water Assessments

### Imported (MWDSC) Water Assessment

Every five years, MWDSC is required by DDW to examine possible sources of drinking water contamination in its State Water Project and Colorado River source waters.

The most recent watershed sanitary surveys of its source water supplies from the Colorado River was updated in 2015 and the State Water Project was updated in 2016.

Water from the Colorado River is considered to be most vulnerable to contamination from recreation, urban/stormwater runoff, increasing urbanization in the watershed, and wastewater. Water supplies from Northern California's State Water Project are most vulnerable to contamination from urban/stormwater runoff, wildlife, agriculture, recreation, and wastewater.

USEPA also requires MWDSC to complete one Source Water Assessment (SWA) that utilizes information collected in the watershed sanitary surveys. MWDSC completed its SWA in December 2002. The SWA is used to evaluate the vulnerability of water sources to contamination and helps determine whether more protective measures are needed.

A copy of the most recent summary of either Watershed Sanitary Survey or the SWA can be obtained by calling MWDSC at (800) CALL-MWD (225-5693).

### Groundwater Assessment

An assessment of the drinking water sources for the City was completed in December 2002. The groundwater sources are considered most vulnerable to the following activities not associated with detected contaminants: drinking water treatment plants, high density housing, motor pools, repair shops, storm drain discharge points, utility stations — maintenance areas, and water supply wells.

A copy of the complete assessment is available at State Water Resources Control Board, Division of Drinking Water, 605 W. Santa Ana Boulevard, Building 28, Room 325, Santa Ana, California 92701.

You may request a summary of the assessment by contacting the City at (714) 690-3310.

## 2017 City of La Palma Distribution System Water Quality

Aesthetic Quality	MCL (MRDL/MRDLG)	Average Amount	Range of Detections	MCL Violation?	Typical Source of Contaminant
Total Trihalomethanes (ppb)	80	21	2.7 – 24	No	Byproducts of chlorine disinfection
Haloacetic Acids (ppb)	60	4	ND – 7.9	No	Byproducts of chlorine disinfection
Chlorine Residual (ppm)	(4 / 4)	1.08	0.43 – 1.35	No	Disinfectant added for treatment
<b>Aesthetic Quality</b>					
Color (color units)	15*	3.9	ND – 20	No	Erosion of natural deposits
Odor (threshold odor number)	3*	0.96	1 – 2	No	Erosion of natural deposits
Turbidity (NTU)	5*	0.73	ND – 1.9	No	Erosion of natural deposits

Eight locations in the distribution system are tested quarterly for total trihalomethanes and haloacetic acids; five locations are tested weekly for color, odor, and turbidity.

MRDL = Maximum Residual Disinfectant Level; MRDLG = Maximum Residual Disinfectant Level Goal

\*Contaminant is regulated by a secondary standard to maintain aesthetic qualities (taste, odor, color).

## Lead and Copper Action Levels at Residential Taps

Action Level (AL)	Public Health Goal	90 <sup>th</sup> Percentile Value	Sites Exceeding AL / Number of Sites	AL Violation?	Typical Source of Contaminant
Lead (ppb)	15	0.2	1 / 32	No	Corrosion of household plumbing
Copper (ppm)	1.3	0.3	0 / 32	No	Corrosion of household plumbing

Thirty-two residences were tested for lead and copper at-the-tap during 2015. Lead was detected in one home, which exceeded the regulatory Action Level. Copper was detected in 25 homes; none exceeded the AL.

A regulatory AL is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

In 2017, a total of two schools submitted requests to be sampled for lead.

## Unregulated Chemicals Requiring Monitoring in the Distribution System

Chemical	Notification Level	PHG	Average Amount	Range of Detections	Most Recent Sampling Date
Chlorate (ppb)	800	n/a	140	93 – 170	2013
Chromium, Hexavalent (ppb)	n/a	0.02**	< 0.03	ND – 0.05	2013
Molybdenum, Total (ppb)	n/a	n/a	12	6.8 – 14	2013
Strontium, Total (ppb)	n/a	n/a	600	490 – 900	2013
Vanadium, Total (ppb)	50	n/a	0.53	ND – 1.8	2013

\*\*There is currently no MCL for hexavalent chromium. The previous MCL of 10 ppb was withdrawn on September 11, 2017.

# Save Money & Water: Learn How to Stop Leaks



Nationwide, more than 1 trillion gallons of water are lost annually due to household leaks. That's equal to the annual water use of more than 11 million homes. The average household can waste more than 10,000 gallons each year due to correctable leaks. That's enough to wash 270 loads of laundry!

Ten percent of homes have leaks that waste 90 gallons or more per day! Common sources include toilets, faucets, showerheads, and landscape irrigation. But you should also consider less obvious sources of leaks: water heaters, ice makers, dishwashers, and filtration systems. Many of these are easily correctable, and fixing them can save about 10 percent on the average water bill.

Be sure to check your toilet for leaks at least once a year. Put food coloring in the tank. If it seeps into the bowl without flushing, there's a leak. And if your toilet flapper doesn't close properly after flushing, replace it. Remember, one drip a second adds up to five gallons lost per day! So regularly check your faucets and showerheads, as well as all hoses and connectors.

Many household leaks can be solved with simple tools and a little education — and fortunately, Do-It-Yourselfers have access to multiple resources. But even if you must pay for repairs, you will still save money in the long run. For more information on water conservation, visit [www.ocwatersmart.com](http://www.ocwatersmart.com).

**This report contains important information about your drinking water.**

**Translate it, or speak with someone who understands it.**

Este informe contiene información muy importante sobre su agua potable. Para más información ó traducción, favor de contactar a Customer Service Representative. Telefono: (714) 690-3310.

이 보고서에는 귀하가 거주하는 지역의 수질에 관한 중요한 정보가 들어 있습니다. 이것을 번역하거나 충분히 이해하시는 친구와 상의하십시오.



## City of La Palma

Community Services Department  
7821 Walker Street  
La Palma, California 90623

PRESORT STD  
U.S. Postage  
**PAID**  
Santa Ana, CA  
Permit #1208

EDDM/ECRWSS

**POSTAL CUSTOMER**

