



**CITY OF LA PALMA  
COMMUNITY SERVICES DEPARTMENT**

**ADDENDUM NO. 1**

**VALLEY VIEW STREET, CITY PROJECT NO. ST-348 AND  
AND ZONE 1 SLURRY SEAL IMPROVEMENTS, CITY PROJECT NO. ST-354**

**APRIL 23, 2019**

**TO ALL REQUEST FOR PROPOSAL RECIEPIENTS:**

Clarifications/Questions from Contractors.

The following addresses questions and offers clarifications to the RFP referenced above and will the information below will be incorporated into the RFP per this Addendum. The answers are provided in bold.

1. Project working days/schedule? ***The City's working day schedule is Monday through Thursday. The Contractor is to provide a statement, on company letterhead, indicating compliance with the City's working day schedule or a shorter working day schedule if the contractor works Monday through Friday. The Contractor is include preliminary schedule with this letter/statement.***

***The City is scheduling Council award for May 21, 2019 and work to begin on June 2, 2019.***

2. When are All No Parking signs are to be posted? ***All No Parking signs are to be posted 72 hours prior to scheduled work to allow PD enforcement and towing.***

3. For work on Valley View, will a traffic control plan be required? ***A signed, by an engineer/traffic engineer shall be prepared for all work in Valley View. No plans will be required for the residential work areas or police department parking lot.***

4. What are the Valley View project limits? ***The limits for the work on Valley View are ONLY the southbound travel lanes, per the attached plans. The attached plans are incorporated into the project specifications. Exclude all slurry work through the La Palma intersection. This is NOT shown in the plans. Include all striping work shown in the plans.***

5. For the PD Parking lot? ***All work is to be coordinated with PD and FD operations. The City will facilitate coordination to allow an open parking lot for pavement repairs and slurry operations. These can be completed in one day for each operation.***

***Parking bumpers are to be removed and replaced for PD parking spaces. The cost for this work is to be incorporated into the current bid items accordingly.***

***There are three traffic loops to be replaced. See attached, revised bid sheet.***

***The grinding/paving quantities have increased. See attached, revised bid sheet.***

***All PD parking lot striping shall be paint.***

6. ***Attached is the sign-in sheet for the bidders that attended the mandatory pre-bid meeting. Only the firms on the sign-in sheet will be allowed to bid on this project.***

7. ***The bid date DOES NOT, Change.***

Please sign below and attach this "ACKNOWLEDGMENT OF RECEIPT", Addendum No. 1 with the bid submittal documents. Thank you for your cooperation.

Sincerely,



Douglas Benash, P.E  
City Engineer

---

**ACKNOWLEDGMENT OF RECEIPT: Addendum No. 1**

\_\_\_\_\_

Company Name

\_\_\_\_\_

Date

By \_\_\_\_\_

Signature